



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA191845

**Certificate Holder:** Jiangsu Goodwe Power Supply Technology Co., Ltd.  
No. 189, Kun Lun Shan Road,  
Suzhou New District, 215163 Suzhou,  
Jiangsu  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** Hybrid Inverter  
**Brand Name:** GOODWE  
**Model No.:** GW6000-EH  
**Markings:** PV Input: 580Vdc Max,  
MPPT voltage range 100-550Vdc 12.5/12.5A  
Isc PV 15.2/15.2A  
Grid input: 230V~ 50Hz 52.2A 12000VA  
Grid output: 230V~ 50Hz 26.1A 6000VA  
Backup: 230V~ 50Hz 26.1A 6000VA  
Battery: 85-450Vdc Charge/Discharge 25/25A  
IP65, Class I

**Standard:** IEC 62109-1 Ed 1.0  
IEC 62109-2 Ed 1.0  
AS/NZS 4777.2:2015

**Conditions:** Nil

**Certification Mark:** SAA191845 or RCM

**Date First Registered:** 15 July 2019

**Date of Expiry:** 15 July 2024


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 15-07-19 191845/1