



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA192403

Date of Issue: 4 September 2019

Class Description: Non-Prescribed

Product Description: PV Inverter (Grid-tied photovoltaic inverter)

General Modification:

Hardware (Firmware) version: 290-10098-00

Software version: V1.00.00.01

Additional Models	Trade Name	Rating
GW4K-DT	GOODWE	Input: MPPT Voltage range: 180-850Vdc, Max 1000Vdc, Max 12.5A/12.5A, Isc: 15.6/15.6A Output: 3/N/PE, 400V~ 50/60Hz, 3x5.8A 4000W
GW4KL-DT	GOODWE	Input: MPPT Voltage range: 180-550Vdc, Max 600Vdc, Max 12.5A/12.5A, Isc: 15.6/15.6A Output: 3/N/PE, 400V~ 50/60Hz, 3x5.8A 4000W
GW5K-DT	GOODWE	Input: MPPT Voltage range: 180-850Vdc, Max 1000Vdc, Max 12.5A/12.5A, Isc: 15.6/15.6A Output: 3/N/PE, 400V~ 50/60Hz, 3x7.3A 5000W
GW5KL-DT	GOODWE	Input: MPPT Voltage range: 180-550Vdc, Max 600Vdc, Max 12.5A/12.5A, Isc: 15.6/15.6A Output: 3/N/PE, 400V~ 50/60Hz, 3x7.3A 5000W
GW6KL-DT	GOODWE	Input: MPPT Voltage range: 180-550Vdc, Max 600Vdc, Max 12.5A/12.5A, Isc: 15.6/15.6A Output: 3/N/PE, 400V~ 50/60Hz, 3x8.7A 6000W

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 04-09-19 192403/2