



太阳能产品认证证书

证书编号：CQC19024217434

申请人名称及地址

江苏固德威电源科技股份有限公司
苏州高新区昆仑山路 189 号（科技城内）

制造商名称及地址

江苏固德威电源科技股份有限公司
苏州高新区昆仑山路 189 号（科技城内）

生产企业名称及地址

江苏固德威电源科技股份有限公司 (V017465)
苏州高新区昆仑山路 189 号（科技城内）

产品名称和系列、规格、型号

光伏并网逆变器

GW5K-DT, GW6K-DT, GW8K-DT, GW10KT-DT (见附件)

产品标准和技术要求

NB/T32004-2018

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2018 认证规则的要求，特发此证。

发证日期：2019 年 04 月 30 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2019 年 04 月 23 日



主任：_____

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

T 0012899



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC19024217434

NAME AND ADDRESS OF THE APPLICANT

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD.
NO.189 Kun Lun Shan Road, Suzhou New District,jiangsu,China

NAME AND ADDRESS OF THE MANUFACTURER

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD.
NO.189 Kun Lun Shan Road, Suzhou New District,jiangsu,China

NAME AND ADDRESS OF THE FACTORY

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD. (V017465)
NO.189 Kun Lun Shan Road, Suzhou New District,jiangsu,China

PRODUCT NAME, MODEL AND SPECIFICATION

Grid-tied PV inverter
GW5K-DT, GW6K-DT, GW8K-DT, GW10KT-DT (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2018

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018 .

Valid from: Apr.30,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Apr.23,2019



President:

A handwritten signature in black ink, appearing to read "陆梅" (Lu Mei).

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

T 0012899



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC19024217434

纸 号: 12899

GW10KT-DT

直流输入:MPPT 电压范围 180V-850Vdc,最大直流输入电压 1000Vdc,最大输入电流 12.5A*2;
交流输出: 3~, 400V, 50Hz, Max. 16A, 额定交流输出功率 10kW;

GW8K-DT

直流输入:MPPT 电压范围 180V-850Vdc,最大直流输入电压 1000Vdc,最大输入电流 12.5A*2;
交流输出: 3~, 400V, 50Hz, Max. 12.8A, 额定交流输出功率 8kW;

GW6K-DT

直流输入:MPPT 电压范围 180V-850Vdc,最大直流输入电压 1000Vdc,最大输入电流 12.5A*2;
交流输出: 3~, 400V, 50Hz, Max. 9.6A, 额定交流输出功率 6kW;

GW5K-DT

直流输入:MPPT 电压范围 180V-850Vdc,最大直流输入电压 1000Vdc,最大输入电流 12.5A*2;
交流输出: 3~, 400V, 50Hz, Max. 8A, 额定交流输出功率 5kW.

注: 此附录与证书同时使用时有效。



主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>