



**BUREAU
VERITAS**

Attestation of Conformity

Attestation No.: 1888AP1008N021006
Equipment: Grid-connected PV Inverter

Brand Name:  **GOODWE**
your solar engine

Test Model No.: GW36K-MT, GW30K-MT, GW25K-MT

Applicant: **Jiangsu GoodWe Power Supply Technology Co., Ltd.**
No.189, Kun Lun Shan Road, Suzhou New District, Jiangsu 215163,
P. R. China

Report No.: PVUK181008N021

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G99/1 for photovoltaic systems with a three-phases parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This automatic disconnection device should be complied with Engineering Recommendation G100 Issue 1 Amendment 1. This automatic disconnection device serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards

Engineering Recommendation G99/1-3:2018

Requirements for the connection of generation equipment in parallel with public distribution networks

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

Name: James Huang
Technical Manager/ New Energy Team
Date: 2019-05-17

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.